



Certificate of Compliance

Certificate: 2560318

Master Contract: 153960

Project: 70003397

Date Issued: February 28, 2014

Issued to: Trafomic OY

**Tuotekatu 15
Raisio, 21200
Finland
Attention: Jarkko Reponen**

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C', 'US' and



Eric Fortier

Issued by: Eric Fortier, Eng.

PRODUCTS

CLASS 5411 86 - TRANSFORMERS - Power - Certified to US Standards

CLASS 5411 06 - TRANSFORMERS-Power

- Control circuit transformers*, Three phases, Skeleton type, air-cooled, rated Primary \leq 600V, Secondary \leq 600V, 50-60Hz, Models 3PU and 3MU; max.; 50 kVA. Insulation Class B/F.

Note(*):

- Certified as components for use with other equipment where the suitability of the combination is to be determined by CSA.

APPLICABLE REQUIREMENTS

C22.2 No. 66.1-06

- Low Voltage Transformers - Part 1: General Requirements



Certificate: 2560318

Master Contract: 153960

Project: 70003397

Date Issued: February 28, 2014

C22.2 No. 66.2-06

- Low Voltage Transformers - Part 2: General Purpose Transformers

UL 5085-1 (1st Ed)

- Low Voltage Transformers - Part 1: General Requirements

UL 5085-2 (1st Ed)

- Low Voltage Transformers - Part 2: General Purpose Transformers